# APPROVAL FOR CONSTRUCTION

CA2012107613 N.H. DEPARTMENT OF ENVIRONMENTAL SERVICES CA2012107613
SUBSURFACE SYSTEMS BUREAU
P.O. BOX 95, 29 HAZEN DRIVE, CONCORD, NH 03302-0095 APPROVAL NO.

THE PLANS AND SPECIFICATIONS FOR SEWAGE OR WASTE DISPOSAL SYSTEM SUBMITTED FOR:

OWNER: THE THREE SOCIOS LLC
321 D LAFAYETTE RD
HAMPTON NH 03842-

COPY SENT TO:
BOARD OF SELECTMEN
PO BOX 660
BARRINGTON NH 03825-0660

BY APPLICANT: PERMIT NO. 01358

JONES & BEACH ENGINEERS INC
PO BOX 219
STRATHAM NH 03885

| | |
|---|---|
| | 239 / 004 |
| Map No./Lot No.: | PRE67 |
| Subd. Appvl. No.: | |
| Subd. Name: | STRAFFORD |
| County: | 3937 |
| Registry Book No.: | 0522 |
| Registry Page No.: | |
| Probate Docket No. (If Applicable): | N |
| Type of System: | BR<br>610 GPD |
| Town/City Location: | BARRINGTON |
| Street Location: | 356 CALEF HIGHWAY |

Subsurface waste disposal systems must be operated and maintained in a manner so as to prevent nuisance or health hazard due to system failure. (RSA 485-A:37)

It is unlawful to discharge any hazardous chemicals or substances into subsurface waste disposal systems. Included are paints, thinners, gasoline and chlorinated hydrocarbon solvents such as TCE, sometimes used to clean failed septic systems and auto parts. (Env-Ws 1503.04)

**ADVISE YOUR CONTRACTOR OF REQUIRED CHANGES IN PLANS AS INDICATED BELOW CONDITIONS**

APPROVED FOR 3000 S.F. CONVENIECE STORE/GAS @ 5 GPD/100 S.F., FAST FOOD (16) SEATS @ 20 GPD/SEAT (PAPER SERVICE ONLY) AND (4) EMPLOYEE @ 35 GPD/EMPLOYEE.

LAND USE OFFICE
FEB 28 2012
RECEIVED

02/21/2012
Approved this date: _____

STANISLAW BOMBA
By: _____
N.H. Department of Environmental Services Staff

Date amended: _____

Amended by: _____ (OVER)

REVISED 8/01

201200397

TOWN'S