HAIGHT ENGINEERING, PLLC

P.O. BOX 1166, 181 WATSON ROAD
DOVER, NH
TEL: (603) 750-4266, FAX: (603)749-7348

February 27, 2015

Barrington Planning Board
572 Calef Highway
Barrington NH 03825

C/o Marcia Gasses, Town Planner

Re: **Driveway Certification**
J.L Powell Construction, LLC
94 Young Road
Lot 240/15-6

Dear Ms. Gasses;

On Friday, 2/27/2015, Haight Engineering, PLLC, performed an as-built survey of the gravel driveway of the above referenced lot. The purpose of the survey was to determine whether or not the driveway grade from the edge of the existing paved apron as constructed was in compliance with Barrington Regulation Article 12.3.2 (4) (Driveway Design).

We hereby certify that the driveway beginning at the edge of the existing paved apron is in compliance with Barrington Regulation Article 12.3.2 (4) (Driveway Design) and does not exceed 10% grade.

If you have any questions please do not hesitate to contact me directly.

Sincerely;

Haight Engineering, PLLC

Stephen J. Haight, P.E.

C. C: J.L. Powell Construction, LLC

Attachment: As-built survey (2/27/15)

STATE OF NEW HAMPSHIRE
STEPHEN J. HAIGHT No. 7978
LICENSED PROFESSIONAL ENGINEER
2/27/15