The State of New Hampshire
DEPARTMENT OF ENVIRONMENTAL SERVICES

Thomas S. Burack, Commissioner

August 2, 2007

Robert Shields Jr.
PO Box 41
Barrington, NH 03825

RE: DES Site Specific File# WPS-7164, Gerrior Lane Trust-Homestead Subdivision / NH Route 4, Barrington and Nottingham, NH

Dear Mr. Shields:

The Department of Environmental Services ("DES") received your request for an extension of the above referenced Site Specific permit. As you are aware, DES conducted an inspection of the project on June 1, 2007 in response to a complaint.

During the inspection, DES made the following observations:

1. The detention pond located at the intersection of Gerrior Drive and St. Matthews is not constructed and stabilized in accordance with approved plans;
2. An unapproved stump dump is located on St. Matthews at the outlet of a culvert, blocking the flow of water;
3. Evidence of erosion on the slopes and in the ditchlines along St. Matthews;
4. Loam pile located on St. Matthews is not stabilized and no erosion controls surround the pile in accordance with approved plans;

Based on the inspection, DES requests that you take the following action:

5. **By September 3, 2007**, provide as-built plans, stamped by a New Hampshire licensed professional engineer, to document to DES that the detention pond located at the intersection of Gerrior Drive and St. Matthews is in compliance with approved plans;
6. **By September 3, 2007**, provide photographic documentation to DES that the stump dump is removed from the outlet of the culvert on St. Matthews;
7. **By September 3, 2007**, provide photographic documentation to DES that the slopes and ditchlines along St. Matthews are stabilized in accordance with approved plans;
8. **By September 3, 2007**, provide photographic documentation that the loam pile located on St. Matthews is stabilized and erosion controls are installed in accordance with approved plans.

Site Specific Permit# WPS-7164

Based on the inspection, DES has determined that the project is not currently in compliance with the approved Site Specific permit. DES will not grant your request for an extension of the Site Specific permit until you have documented, as described above, that the project is in compliance with RSA 485-A:17.

Please include the file number (WPS-7164) on all correspondence and provide the Barrington and Nottingham Conservation Commissions a copy of all information submitted to this office.

If you have any questions, please contact me at (603) 559-1514 or by email at *dprice@des.state.nh.us*

Sincerely,

David Price

David Price
East Region Compliance Investigator
DES Wetlands/Alteration of Terrain

DAP/dap

ec: Ridge Mauck, DES Alteration of Terrain
Natalie Landry, DES Watershed Management

cc: Barrington Conservation Commission
Nottingham Conservation Commission
Ted Buczek, Barrington Code Enforcement
Peter Cook, Barrington Road Agent
Mike Seivert, MJS Engineering
Ian Trefry, NHSC, Inc.

F:\Files\alteration of terrain\enforcement letters\wps-7164 gerrior drive barrington-nottingham.doc