

APPROVAL FOR CONSTRUCTION

CA2012107613

N.H. DEPARTMENT OF ENVIRONMENTAL SERVICES

CA2012107613

SUBSURFACE SYSTEMS BUREAU

P.O. BOX 95, 29 HAZEN DRIVE, CONCORD, NH 03302-0095

APPROVAL NO.

THE PLANS AND SPECIFICATIONS FOR SEWAGE OR WASTE DISPOSAL SYSTEM SUBMITTED FOR:

OWNER: THE THREE SOCIOS LLC
321 D LAFAYETTE RD
HAMPTON NH 03842-

Map No./Lot No.: 235/004
Subd. Appvl. No.: PRE67
Subd. Name: STRAFFORD
County: 3037
Registry Book No.: 0522
Registry Page No.:
Probate Docket No.:
(If Applicable)

COPY SENT TO: BOARD OF SELECTMEN
PO BOX 680
BARRINGTON NH 03825-0680

Type of System: N
BR
610 GPD
BARRINGTON

Town/City Location: 350 CALEF HIGHWAY

BY APPLICANT: PERMIT NO. 01358

JONES & BEACH ENGINEERS INC
PO BOX 219
STRATHAM NH 03885

Street Location:

Subsurface waste disposal systems must be operated and maintained in a manner so as to prevent nuisance or health hazard due to system failure.
(RSA 485-A:37)

It is unlawful to discharge any hazardous chemicals or substances into subsurface waste disposal systems. Included are paints, thinners, gasoline and chlorinated hydrocarbon solvents such as TCE, sometimes used to clean failed septic systems and auto parts. (Env-Ws 1503.04)

ADVISE YOUR CONTRACTOR OF REQUIRED CHANGES
IN PLANS AS INDICATED BELOW CONDITIONS

APPROVED FOR 3000 S.F. CONVENIENCE STORE/GAS @ 5 GPD/100 S.F., FAST FOOD (16) SEATS @ 20 GPD/SEAT (PAPER SERVICE ONLY) AND (4) EMPLOYEE @ 35 GPD/EMPLOYEE.

LAND USE OFFICE

FEB 28 2012

RECEIVED

02/21/2012

Approved this date: _____

Date amended: _____


STANISLAW BOMBA

By: _____
N.H. Department of Environmental Services Staff

Amended by: _____ (OVER)

REVISED 8/01

201200367

TOWN'S