



November 18, 2014

Ms. Marcia Gasses
Town Planner and Land Use Administrator
Town of Barrington
P.O. Box 660
Barrington, New Hampshire 03825

Subject: TurboCAM – Map 234 / Lot 1.5 – TurboCAM
Drainage Report Engineering Review

Dear Ms. Gasses:

As requested, we have completed our review of the Drainage Report submitted for the above-referenced project. For this subsequent review, we did not receive a full revised plan set or Drainage Report. The information we did receive and reviewed are the following:

- Full and 11x17 sheet size of Sheet C2 – Grading, Drainage, Utilities & Erosion Control Plan and Sheet C9 – Construction Details with a latest revision date of 11/12/14.
- An 11x17 sheet size of Topoquad with Watershed Overlay with a date of 11/12/14.

The following were comments noted during the review.

1. The Drainage Report does not reference the source (i.e. Appendix A of the NH Stormwater Manual – Vol. 2, USDA – NRCS, NHDES – AoT Website, etc.) of the rainfall data modeled.
(repeat comment)
2. Although the response letter stated the results of the percolation test supporting the infiltration rate, we would recommend that the test results (field report) be incorporated in to the Drainage Report for documentation.
(repeat comment)

If you have any questions or comments, please do not hesitate to contact us.

Very truly yours,

DuBOIS & KING, Inc.

Scott M. Bourcier, P.E.
Project Manager

Approved by:

Jeffrey A. Adler, P.E.
Sr. Project Manager

SMB / js

cc. MJS Engineering, PC
TurboCAM