

# HAIGHT ENGINEERING, PLLC

P.O. BOX 1166, 181 WATSON ROAD

DOVER, NH

TEL: (603) 750-4266, FAX: (603) 749-7348

---

February 27, 2015

Barrington Planning Board  
572 Calef Highway  
Barrington NH 03825

C/o Marcia Gasses, Town Planner

Re: **Driveway Certification**  
**J.L Powell Construction, LLC**  
**94 Young Road**  
**Lot 240/15-6**

Dear Ms. Gasses;

On Friday, 2/27/2015, Haight Engineering, PLLC, performed an as-built survey of the gravel driveway of the above referenced lot. The purpose of the survey was to determine whether or not the driveway grade from the edge of the existing paved apron as constructed was in compliance with Barrington Regulation Article 12.3.2 (4) (Driveway Design).

We hereby certify that the driveway beginning at the edge of the existing paved apron is in compliance with Barrington Regulation Article 12.3.2 (4) (Driveway Design) and does not exceed 10% grade.

If you have any questions please do not hesitate to contact me directly.

Sincerely;

**Haight Engineering, PLLC**



Stephen J. Haight, P.E.

C. C: J.L. Powell Construction, LLC

Attachment: As-built survey (2/27/15)

