



November 24, 2019

Ms. Marcia Gasses, Town Planner
Town of Barrington
P.O. Box 660
Barrington, New Hampshire 03825

Subject: River's Peak – Map 215 / Lot 1
Wearing Course Pavement Observations

Dear Ms. Gasses:

As requested, DuBois & King performed wearing course pavement observations of the above-referenced project's subdivision roadway from Boulder Drive to end (approx. Sta. 30+54.85). Observation for the wearing course pavement was performed on November 7, 2019, while confirmation of the shoulder leveling gravel placement was performed November 21, 2019. The following were comments recorded during the observations.

1. The wearing course pavement width met the 24-foot travel way and 1-inch compacted depth requirements.
2. Placement of the wearing course pavement met the New Hampshire Department of Transportation (NHDOT) Standard Specifications for Road and Bridge Construction (dated 2010) specifications, except for surface temperature requirement; please see Field Report dated 11/07/19.
3. The shoulder leveling gravel met the 4-foot width requirement; and,
4. There are some outstanding punch list items to be completed as of the date of this letter.

If you have any questions or concerns, please do not hesitate to contact us.

Very truly yours,
DuBOIS & KING, Inc.

Scott M. Bourcier, P.E.
Project Manager

SMB/smb

I:\31323138P - Barrington - Rivers Peak Insp\Const\LETTER_Barrington (19) 11-24.doc