

Site Plan Waiver Request Form
Under Site Plan Regulations 3.9.8-Waivers and Article 8-Waiver Procedure

If there is more than one waiver requested, each waiver request is to be individually listed and described, as each waiver is considered individually by the Town of Barrington Planning Board. A petition for waiver shall be submitted in writing by the applicant with the application for review. The request shall fully state the grounds for which the waiver is requested and all facts supporting this request with reference to the applicable Barrington Site Plan Regulations article, section and paragraph. **Each waiver granted shall be listed on the approved site plan.**

Name of Site Plan (See Title Box): BARRINGTON TOWN HALL

Case Number: 223-26(C1) RC / SDOA-20-SR

Site Location: CALEF HIGHWAY - RT 125

Zoning District(s): RC / SDOA

Owner (s): RT 125 DEVELOPMENT, LLC

Address of Owner(s): 7B EMERY LAND, STRATHAM, NH, 03885

Address Line 2: _____

Name of Applicant (if different from owner): CONNOR MACIVER - TOWN MANAGER


Phone Number 603-664-9007 Email CMACIVER@BARRINGTON.NH.GOV

Land Surveyor: GEOFFREY ALEVA, PE - CIVIL CONSULTANTS

I, GEOFFREY ALEVA seek the following waiver to the Town of Barrington Site Plan regulations for the above case submittal:

SECTION 4.7.7.(3) - MINIMUM DEPTH OF COVER FOR STORM DRAIN LINES OF 36 INCHES.

THIS PROJECT HAS STORM DRAIN PIPES THAT WILL HAVE PORTIONS OF ITS INSTALLATION WHERE SOIL COVER IS NOT 36 INCHES. THESE LOCATIONS ARE REQUIRED DUE TO SITE GRADING OF PIPE PLACEMENT. THE INSTALLATION OF THE PIPES WILL FOLLOW STANDARD ENGINEERING PRACTICES AND WILL NOT CREATE A DETRIMENT TO THE PROJECT.

 4/20/2020

Signature of Owner/Applicant

Date

Site Plan Waiver Request Form

Under Site Plan Regulations 3.9.8-Waivers and Article 8-Waiver Procedure

If there is more than one waiver requested, each waiver request is to be individually listed and described, as each waiver is considered individually by the Town of Barrington Planning Board. A petition for waiver shall be submitted in writing by the applicant with the application for review. The request shall fully state the grounds for which the waiver is requested and all facts supporting this request with reference to the applicable Barrington Site Plan Regulations article, section and paragraph. Each waiver granted shall be listed on the approved site plan.

Name of Site Plan (See Title Box): BARRINGTON TOWN HALL

Case Number: 223-26(C1) RC / SDOA-20-SR

Site Location: CALEF HIGHWAY - RT 125

Zoning District(s): RC / SDOA

Owner (s): RT 125 DEVELOPMENT, LLC

Address of Owner(s): 7B EMERY LAND, STRATHAM, NH, 03885

Address Line 2: _____

Name of Applicant (if different from owner): CONNOR MACIVER - TOWN MANAGER


Phone Number 603-664-9007 Email CMACIVER@BARRINGTON.NH.GOV

Land Surveyor: GEOFFREY ALEVA, PE - CIVIL CONSULTANTS

I GEOFFREY ALEVA seek the following waiver to the Town of Barrington Site Plan regulations for the above case submittal:

SECTION 4.7.7.(1) - SITE PLAN REGULATIONS - MINIMUM PIPE DIAMETER STORM DRAIN SYSTEMS OF 15 INCHES.

THIS PROJECT HAS TWO PIPES OF 12 INCH DIAMETER. THESE PIPES HAVE BEEN DESIGNED FOR CONTROLLED FLOWS AND WILL ACCOMMODATE THE FLOW OF STORMWATER THROUGH THE PIPE. THESE PIPES CAN ALSO BE EASILY CLEANED IF REQUIRED FOR MAINTENANCE. THE INSTALLATION OF CULVERTS OF THIS SIZE WILL NOT BE A DETRIMENT TO THE PROJECT.

 4/20/2020

Signature of Owner/Applicant

Date