



Barrington Fire Department

TEL (603) 664-2241 • FAX (603) 664-5417

Incorporated in 1944

Mr. Robert Russell
99 Tolend Rd.
Barrington NH 03825
DBA 2A Tactical

October 5, 2021

Dear Mr. Russell

On Wednesday September 29th you invited Inspector Plante of the NH Fire Marshal's Office and I onto your property located at 99 Tolend Road Barrington where you operate your business, 2A Tactical. You requested a hazardous material inspection based on the Home Occupation provisions of the zoning ordinance. We did not encounter any hazardous materials of concern while we were there.

I did notice several potential fire code violations while we were conducting our hazardous materials inspection.

Some of my concerns include:

- Unprotected temporary wiring between your storage containers.
- The tent being used as part of your business and its use as part of the ingress/egress for your business.
- The use of temporary wiring in multiple locations throughout the business.
- I question if there is adequate ventilation for your test fire area.
- Secondary exits for employees and customers from all areas of the business.
- The occupant load for the business must be determined, I am concerned that with the current layout of your business your occupant load will be an issue.

These are just some of my observations, there may be other issues that will arise during a full Life Safety Code inspection. If you plan to continue operating your business at 99 Tolend Road, a full inspection and compliance with the Fire Code is required. Please let me know your intentions by October 25th.

Respectfully

Rick Walker, Fire Chief
Barrington Fire & Rescue

Cc: Barrington Zoning Board of Adjustment
Conner MacIver, Town Administrator
Laura Spector-Morgan, Esquire
Brendan O'Donnell, Esquire