

Barbara Irvine

From: Marc Moreau
Sent: Saturday, January 22, 2022 2:59 PM
To: ClassVI
Subject: 68 Rocky Point Rd

I have inspected the road along the frontage of 68 Rocky Point Road and will make the following observations . The entire length of Rocky Point Road is paved and in relatively good condition ,but in no place is it wider than about 13 feet ,therefore does not meet the minimum Town requirements of 16 feet with 2 foot shoulders ,if this project comes under these restrictions. If the work proceeds as conditions are currently,care should be taken to avoid damage to existing pavement ,and repair any pavement that is inadvertently damaged due to construction activities.
It is also so suggested that the property owner joins the road association, if not a member already.

Marc Moreau
Barrington NH Road Agent

Get [Outlook for Android](#)

TOWN OF BARRINGTON CONFIDENTIALITY AND DISCLOSURE NOTICE:

This email and any email to employees and officials of the Town of Barrington may be subject to public disclosure under the New Hampshire Right to Know law (RSA 91-A). However, this message may also contain information that is privileged and confidential which may be legally protected from disclosure. If you are not the intended recipient of this message or their agent, or if this message has been addressed to you in error, please immediately alert the sender by reply email and then delete this message and any attachments. If you are not the intended recipient, you are hereby notified that any use, dissemination, copying, or storage of this message or its attachments is strictly prohibited.